

Message Text

UNCLASSIFIED

PAGE 01 BANGKO 05619 151222Z
ACTION EA-09

INFO OCT-01 ISO-00 EB-08 /018 W
-----151233Z 038313 /22

R 150913Z MAR 77
FM AMEMBASSY BANGKOK
TO USDOC WASHDC
INFO SECSTATE WASHDC 0101
AMCONSUL HONG KONG
AMEMBASSY SINGAPORE
AMEMBASSY MANILA

UNCLAS BANGKOK 5619

MANILA PASS USADB

E.O. 11652: N/A
TAGS: BEXP, TH
SUBJ: FOREIGN GOVERNMENT TENDER

1. 549/01/T 0059

2. 031477

3. W. BARMON

4. 549 THAILAND

5. Q

6A. SUBMIT BID TO --

6B. --

6C. METROPOLITAN WATER WORKS AUTHORITY (MWWA), SIYAK MANSRI,
BAMRUNGMUANG, BANGKOK.

UNCLASSIFIED

UNCLASSIFIED

PAGE 02 BANGKO 05619 151222Z

7. PAW-3

8. 051777 AT 10:00 A.M.

9. 201

10. 3824298 - VENTURIMETER; THE METER SYSTEM WILL INCLUDE, BUT

IS NOT LIMITED TO, THE FOLLOWING:

- FLOW MEASURING DEVICE (SHORT VENTURI OR DALL TUBE) AND APPURTINANCES, OVERALL LENGTH SHALL NOT EXCEED TWO TIMES ITS NORMAL PIPE DIAMETER OF 200 MM., WITH CAPACITY TO MEASURE RATE OF FLOW OF AT LEAST 0-350 M3/HR. AND SHALL HAVE A WORKING PRESSURE OF AT LEAST 10 KG/M2.
- ALL VALVES, PIPING, FITTINGS, ADAPTORS AND APPURTENANCES REQUIRED.
- RECORDER FOR RECORDING FLOW AND PRESSURE AND FOR TOTALLING FLOW WITH APPURTENANCES INCLUDING AIR PURGING COMPONENTS.
- SPECIAL TOOLS.
MANUFACTURERS OF THE MEASURING DEVICES AND READING DEVICES MUST HAVE AT LEAST 10 YEARS PRODUCTION EXPERIENCE. ALL COMPONENTS AND ACCESSORIES SHALL BE SUITABLE FOR TROPICAL CLIMATE (TEMPERATURE UP TO AT LEAST 50 DEGREE C).

3589291 - INTEGRATED AND COORDINATED CHLORINATION SYSTEM; THE SYSTEM SHALL INCLUDE, BUT IS NOT LIMITED TO, THE FOLLOWING:

1. SUPPLY WATER BOOSTER PUMP WITH CLOSE COMPLETE OR DIRECT COUPLE ELECTRIC MOTOR AND APPURTENANCES.
2. CHLORINATOR AND APPURTENANCES INCLUDING CHLORINE GAS FEED RATE CONTROLS, CHLORINE GAS FEED RATE INDICATOR,

UNCLASSIFIED

UNCLASSIFIED

PAGE 03 BANGKO 05619 151222Z

AND CHLORINE GAS PRESSURE REGULATOR.

3. EJECTOR (INJECTOR) FOR PROVIDING THE VACUUM TO OPERATE THE CHLORINATOR AND FOR MIXING THE CHLORINE GAS AND SUPPLY WATER AND FEEDING THE CHLORINE SOLUTION INTO WATER DISCHARGED FROM THE WELL PUMP.

4. SUPPLY WATER PRESSURE GAUGES AND CHLORINE GAS PRESSURE GAUGES

5. SUPPLY WATER STRAINER.

6.1 CONNECTION AND APPURTENANCES FOR THE CHLORINE GAS SUPPLY TANK.

7 ALL NECESSARY PIPING, FITTINGS AND APPURTENANCES FOR THE WATER SUPPLY.

8. ALL NECESSARY PIPING, FITTINGS AND APPURTENANCE FOR

THE CHLORINE GAS FEED.

9. ALL NECESSARY PIPING, FITTINGS AND APPURTENANCES FOR
THE CHLORINE SOLUTION FEED.

THE CHLORINATOR AND CHLORINATION SYSTEM SHALL HAVE THE FOLLOWING
CAPACITIES AND CAPABILITIES:

CHLORINATOR GAS FEED CAPACITY	AT LEAST 1 KG/HR.
GAS FEED RATE ACCURACY	WITHIN 4 PERCENT
GAS FLOW METERING TUBE CAPACITY	50-1000 GMS/HR.
GAS FLOW METERING TUBE RANGE	20 : 1
WATER SUPPLY	
AVERAGE OPERATING BACK PRESSURE	4 KG/ CM2
MAXIMUM OPERATING BACK PRESSURE	10 KG/CM2
AVERAGE WATER TEMPERATURE	32 DEGREE C
AMBIENT AIR TEMPERATURE RANGE	10 DEGREE C
CONDITIONS OF SERVICE	TROPICAL

UNCLASSIFIED

UNCLASSIFIED

PAGE 04 BANGKO 05619 151222Z

11. PROJECT FINANCED BY ADB LOAN. TENDER DOCUMENTS ARE FOR SALE
AT \$125 PER SET FROM ADDRESS MENTIONED IN 6C. UNTIL MAY 16.
WHITEHOUSE

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01-Jan-1994 12:00:00 am
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Sent Date: 15-Mar-1977 12:00:00 am
Decaption Date: 01-Jan-1960 12:00:00 am
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01-Jan-1960 12:00:00 am
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1977BANGKO05619
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D770088-0744
Format: TEL
From: BANGKOK
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1977/newtext/t19770360/aaaacanq.tel
Line Count: 143
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: 813a7bb8-c288-dd11-92da-001cc4696bcc
Office: ACTION EA
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: n/a
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 05-Oct-2004 12:00:00 am
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3111913
Secure: OPEN
Status: NATIVE
Subject: FOREIGN GOVERNMENT TENDER
TAGS: BEXP, TH
To: COM
Type: TE
vdkgvwkey: odhc://SAS/SAS.dbo.SAS_Docs/813a7bb8-c288-dd11-92da-001cc4696bcc
Review Markings:
Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
22 May 2009
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009